



Mike DeWine, Governor
John Kasich, Governor
Tom Kopy, Director

September 9, 2013

Andy Walther
Columbia Road LTD
8244 Columbia Road
Pataskala, Ohio 43026

**RE: Construction Storm Water Inspection at Cumberland Trails / Licking
County
Permit Number: 4GC00522*AG**

Dear Mr. Walther:

This letter is written regarding a storm water inspection I conducted by at Cumberland Trails on August 5, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The centralized temporary sediment basin is installed. At this time, corrective measures are expected to ensure all affected areas are routed to this sediment basin for proper sediment control. This would include the installation of a diversion ditch on the extreme eastern end of the property to ensure positive flow to the basin. All bleeder ditches routed to inlet protections must be eliminated and redirected into the sediment basin.
- The large waste stock pile on the southern end of the site will require seeding and mulching to ensure effective erosion control.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is

Andy Walther
Columbia Road LTD
Page -2-

found at: Cumberland Trails 8-5-13. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely



Harry Kallipolitis
Storm Water Coordinator
Ohio EPA
Division of Surface Water

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO