



John E. Kasich, Governor
Mary Taylor, Lt. Governor
Scott S. Martin, Director

September 10, 2013

Randy Tambourine
Ramco-Gershenson Inc. for Lane Avenue, 450 LLC
31500 Northwestern Highway, Suite 300
Farmington Hills, Michigan 48334

RE: Notice of Termination Inspection at Whole Foods- The Shops on Lane Avenue / Franklin County, Permit Number: 4GC03506*AG

Dear Mr. Tambourine:

This letter is written in follow up to a construction storm water inspection by Rachel Bellis and Sam Marotta, of the Ohio EPA at Whole Foods located at 1555 West Lane Avenue on August 8, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

It appeared during the inspection that construction activity has been completed for this site. A Notice of Termination form is required provided the following items are addressed:

- All areas must be protected from erosion measured by a minimum vegetative density of 70 percent for all disturbed areas.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCOA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- If the vegetative requirements above are met please submit your Notice of Termination (NOT) concurrent with your submittal of the post construction

Randy Tambourine
Ramco-Gershenson Inc. for Lane Avenue
Page -2-

verification. The NOT form can be found at:
http://www.epa.state.oh.us/portals/35/documents/NOT_form_09_07.pdf

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO