



September 5, 2013

Brett Kaufman  
Kaufman Development  
30 Warren Street  
Columbus, Ohio 43215

**RE: Construction Storm Water Inspection at 801 Polaris Extended Stay / Delaware County,  
Permit Number: 4GC03902\*AG**

Dear Mr. Kaufman:

This letter is written regarding a storm water inspection conducted by Sam Marotta and Elizabeth Pieta of the Ohio EPA at 801 Polaris Extended Stay at 801 Polaris Parkway on August 12, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- The entrances of the site must be stabilized to minimize off site vehicle tracking.
- Continue to monitor silt fencing for proper function.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Ohio EPA  
Division of Surface Water

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/stw

801 Polaris Extended Stay 8-12-13