



John R. Kasich, Governor  
Timothy J. Meyer, Lt. Governor  
John J. L. ... , Director

September 10, 2013

Jeff Krebs  
Lincoln Construction INC  
4790 Shuster Road  
Columbus, OH 43214

RE: Construction Storm Water Inspection at The Crossing Community Church/ Franklin County,  
Permit Number: 4GC03936 \*AG

Dear Mr. Krebs,

This letter is written regarding a storm water inspection conducted by Jerome Hoke and Elizabeth Pleta of the Ohio EPA at located at 4770 Britton Parkway on August 19, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- The sediment and erosion controls at this site are currently functioning properly. Please continue to monitor and ensure continued compliance with the General Storm Water Permit Associated with Construction Activities.
- Please ensure positive flow towards sediment impoundments to ensure effective sediment control during all phases of construction.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Ohio EPA, Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/slw

The Crossing Community Church 8-19-13