



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

September 10, 2013

Re: Belmont County
 Fox Shannon WWTP
 Self-Monitoring Report Violations
 NPDES Permit OPG00063*DD

Belmont County Commissioners
 Belmont County Courthouse
 101 W. Main Street
 St. Clairsville, Ohio 43950

Dear Commissioners:

We have received your self-monitoring reports covering the months of June and July 2013 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
June 2013	001	Nitrogen, Ammonia (NH3)	30D Conc	1.11	1.149	6/1/2013
July 2013	001	Nitrogen, Ammonia (NH3)	7D Conc	1.67	1.73143	7/8/2013
July 2013	001	Nitrogen, Ammonia (NH3)	7D Conc	1.67	1.90571	7/15/2013
July 2013	001	Nitrogen, Ammonia (NH3)	30D Conc	1.11	1.3471	7/1/2013


Notes: 1D Conc = Daily Average Concentration Value
 1D Qty = Daily Average Loading Value
 7D Conc = Weekly Average Concentration Value
 30D Conc = Monthly Average Concentration Value
 7D Qty = Weekly Average Loading Value
 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have not already done so, please inform this office, in writing, within ten (10) days of receipt of this notification, as to the reasons for the above-referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5416 or nick.hammer@epa.ohio.gov.

Sincerely,

A handwritten signature in blue ink that reads "Jennifer M. Witte for". The signature is written in a cursive style.

Nicholas G. Hammer, R.S.
Permits and Enforcement Section
Division of Surface Water

NH/dh

- c: Mark Esposito, BCSSD
- c: Ron Pacifico, BCSSD