



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

September 12, 2013

RE: CUYAHOGA COUNTY  
VILLAGE OF GATES MILLS  
SUFFOLK ESTATES FORCE MAIN  
PTI APPLICATION NO. 945337  
RECEIVED AUGUST 19, 2013

Christopher Courtney, P.E.  
Gates Mills Village Engineer  
700 Beta Drive, Suite 200  
Cleveland, Ohio 44143

Dear Mr. Courtney:

This letter is a follow-up to our telephone conversation on September 11, 2013 regarding the Permit-to-Install (PTI) application and detailed plans for the above referenced project. Our review noted that the following item(s) must be addressed before the application and plans can be recommended for approval by the Director of Ohio EPA:

- We understand that the size of the replacement force main has been increased from six inches to eight inches. Please revise the plan sheets and application forms as appropriate.
- Form B1, Item 2, as well as the plans, denotes ASTM D-3139 as the selected joint specification. The applicable joint specifications for HDPE pipe are either ASTM F1290 or ASTM F2620.
- The Sewer Use Ordinance date listed on Form B1, Item 10 appears to be incorrect.

Please submit the requested information to my attention. To expedite processing of the revisions, please reference the above PTI number in your response.

Should you have any comments or questions regarding this letter, please contact this office at (330) 963-1196.

Respectfully,

A handwritten signature in black ink, appearing to read "Ermelindo Gomes".

Ermelindo Gomes  
Environmental Engineer  
Division of Surface Water

EG/cs