



John E. Kasich, Governor
Mary Taylor, Lt. Governor
Scott L. Melby, Director

September 12, 2013

Tucker Bohm
The Daimler Group
1533 Lake Shore Drive
Columbus, Ohio 43204

**Re: Storm Water Inspection at Perimeter Retail Development/ Franklin County, Permit Number:
4GC04080*AG**

Dear Mr. Bohm:

This letter is written in follow up to a construction storm water inspection by Elizabeth Pleta and Jerome Hoke of the Ohio EPA, at Perimeter Retail Development located at 6566 Perimeter Drive on August 19, 2013. The purpose of the inspection was to evaluate compliance with Ohio EPA's General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- The area in the southeast corner of the site requires the extension of silt fence to ensure all affected areas are controlled (See Figure 1).

21 Day Rule:

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/slw

Perimeter Retail Development 8-19-13




Figure 1 Southeast corner of site requires the installation of silt fence.