



John Kasich, Governor
Glenn Taylor, Lt. Governor
Scott L. Smith, Director

September 16, 2013

Maronda Homes
3811 Twin Creeks Drive
Columbus, OH 43204

**Re: Notice of Violation
Chevington Place, Madison County**

To Whom it May Concern:

This letter is written regarding the storm water inspection I conducted on September 3, 2013, of the construction activities at Chevington Place, located along US 42, in London, Ohio. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. There were numerous active home sites under construction during my inspection. Please consider this a formal notice of violation. You will need to address the issues below. Based on the site inspection and the General Storm Water Permit, the following need to be addressed at the site:

Sediment and Erosion Controls:

- The active home construction sites need to have straw waddles or silt fence installed around the perimeter or at least on the down slope. Sediment is discharging on to the road. Please see attached pictures.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. Most of the active sites were at or near final grade.
- Please maintain the concrete wash-out pit. Concrete wash-out waste was being discharged to the road.

Maronda Homes
Chevington Place
Page -2-

- Dandy bags need to be installed and maintained on the storm water drains.
- Please have the contractors apply as a co-permittee on the storm water permit

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,



Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

Enclosure