



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

September 16, 2013

Re: Washington County
Beverly WWTP
Self-Monitoring Report Violations
Ohio EPA Permit OPB00002*HD

Beverly WWTP
522 State Route 60
Beverly, OH 45715

We have received your self-monitoring report covering the month of June 2013 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Type	Date	Reporting Code	Parameter	Limit Type	Permit Limit	Reported Value
001	Limit	6/1/2013	31616	Fecal Coliform	Weekly Conc.	2000	3287.85
001	Code	6/14/2013	31616	Fecal Coliform			AK

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets and

U.S. EPA's Facility Pollution Prevention Guide, (EPA/600/R-92/088), you may contact the Ohio EPA Pollution Prevention Section at (614) 644-3469 or me for additional information.

If there are any questions, please contact this office.

Sincerely,

A handwritten signature in black ink, appearing to read "Stephen Wells", written in a cursive style.

Stephen Wells
District Representative
Division of Surface Water

SW/dh