



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

September 18, 2013

Re: Washington County
Deerfield Estates WWTP
Self-Monitoring Report Violations
Ohio EPA Permit OPG00064*DD

Deerfield Estates WWTP
Washington County Commissioners
223 Putnam Street
Marietta, Ohio 45750

We have received your self-monitoring report covering the month of July 2013 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Type	Date	Reporting Code	Parameter	Limit Type	Permit Limit	Reported Value
001	Freq	7/1/2013	00610	Nitrogen, Ammonia (NH3)	1/Month	1	0

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets and

U.S. EPA's Facility Pollution Prevention Guide, (EPA/600/R-92/088), you may contact the Ohio EPA Pollution Prevention Section at (614) 644-3469 or me for additional information.

If there are any questions, please contact this office.

Sincerely,

A handwritten signature in black ink, appearing to read "Stephen Wells". The signature is fluid and cursive, with a long horizontal stroke extending from the end.

Stephen Wells
District Representative
Division of Surface Water

SW/dh