



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

September 20, 2013

Mayor and Council
City of Dayton
101 West Third Street
Dayton, Ohio 45401

RE: Montgomery County, Dayton WWTP, NPDES Permit Violations

Ladies and Gentlemen:

We have reviewed your Discharge Monitoring Reports (DMRs) covering the months of September 2012 through August 2013 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0024881; OEPA Permit # 1PF00000*ND). The specific instances of noncompliance were as follows:

Effluent Limit Violations for September 2012 through August 2013

Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
April 2013	DO	Daily	mg/l	5.0	1.0
August 2013	Fecal Coliform	Weekly	#/100 ml	2000	"AK"

Please be advised that failure to comply with the effluent limitations of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your reports addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

Ned Sarle
Environmental Specialist
Division of Surface Water
Permit Section

NS/kb

cc: Jason Tincu, City of Dayton