



John E. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Hardy, Director

September 23, 2013

Hanlin Rainaldi Construction Corporation  
6610 Single Tree Drive  
Columbus, Ohio 43229

**RE: Construction Storm Water Inspection at Sam's Club #6326-04, Reynoldsburg / Franklin County, Permit Number: 4GC03046\*AG**

Dear Sir or Madam,

This letter is written regarding my site observation of the post construction water quality treatment measures noted at Sam's Club in Reynoldsburg, Ohio on May 23 and June 5, 2013. Based on my recent evaluations of the post construction water quality plan, it is apparent that the 3-inch diameter orifice has not been installed. This orifice is necessary to accommodate the required drain times to meet the intent of the post construction water quality treatment criteria in your General Storm Water Permit.

Failure to implement post construction measures within 30 days will result in a direct recommendation of enforcement from the Director of the Ohio EPA.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Ohio EPA, Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HKGslw Sam's Club #6326 Reynoldsburg 9-6-13