



John E. Kasich, Governor  
Mike Taylor, Lt. Governor  
Scott L. Walke, Director

September 19, 2013

Kent Weakley  
Nationwide Childrens Hospital  
5680 Venture Drive  
Dublin, Ohio 43017

**RE: Construction Storm Water Inspection at Nationwide Childrens Hospital Close to Home  
FAC/ Union County. Permit Number: 4GC04200\*AG**

Dear Mr. Weakley,

This letter is written regarding a storm water inspection conducted by Jerome Hoke of the Ohio EPA at Nationwide Childrens Hospital Close to Home FAC located at 100 Colemans Crossing Boulevard on August 28, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- The sediment impoundment on site requires a temporary riser and/or skimmer. The riser must be set to an elevation to accommodate the required dewatering volume of 67 cubic yards per acre of drainage.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A follow up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Ohio EPA

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO