



OHIO *moving forward*

John E. Kasich, Governor
Randy Taylor, Lt. Governor
Robert Entz, Director

September 19, 2013

James Page
Page Engineering INC
112 East Fifth Street
PO Box 392
Marysville, OH 43040

**RE: Construction Storm Water Inspection at North Main Motors/ Union County,
Permit Number: 4GC03993*AG**

Dear Mr. Page,

This letter is written regarding a storm water inspection conducted by Jerome Hoke of the Ohio EPA at North Main Motors located at 1001 East Fifth Street on August 28, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- An improperly contained concrete washout was noted on the west side of the site (See Figure 1). Proper containment measures are expected within three (3) days from receipt of this letter.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

James Page
Page Engineering INC
Page 2

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (***email preferred***) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Ohio EPA, Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO




Figure 1: Improperly contained concrete waste .it.