



John W. Kasich, Governor  
Randy Hatfield, Lt. Governor  
Scott L. Walby, Director

September 25, 2013

Kirk McMahon  
Circleville City Schools  
388 North Clark Drive  
Circleville, OH 43113

**Re: Notice of Violation  
Circleville City Schools Campus / Pickaway County  
Storm Water General Construction Permit #4GC03589\*AG**

Dear Mr. McMahon:

This letter is written in follow-up to a construction storm water inspection that I conducted on September 18, 2013, at Circleville City Schools Campus project that is located along Clark Drive. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. Please be aware that this is a formal notice of violation. There was active construction at the site during the inspection. Based on my site inspection and the conditions set forth in the General permit, the following items were noted:

**Sediment and Erosion Controls:**

I spoke a representative of Monarch Construction Company, contractor for the high school building and reviewed his weekly inspection forms. The inspections were up-to-date. Monarch representatives stated that the barren areas will be stabilized in October of 2013. No other issues noted at the high school building site.

I was unable to contact a person from Altman General Contractors, contractor for the elementary school building, during my site inspection. There were violations at the elementary school site. There was an illicit discharge to a storm water drain. There was red and white staining on the ground around the storm water drain that had discharged from the concrete operation. Please see attached pictures. In the past, I have requested a berm around the cement operation at the Altman site. A discharge from this site has been discharging to a storm water drain. Please provide a written statement within fourteen days from the date of this letter

Kirk McMahon  
Circleville City Schools  
Page -2-

detailing the nature of the discharge and the controls that will be placed around the operation. Please maintain erosion controls at the site.

Please stabilize the barren areas at the elementary school site.

Please provide the last three months of your weekly inspection log for the elementary school site. Please e-mail the inspection log to [greg.sanders@epa.state.oh.us](mailto:greg.sanders@epa.state.oh.us).

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,



Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

Enclosure

c: Martha Horvitz, Legal, Ohio EPA  
Kevin Mohler, Bovis Lend Lease  
Marty Crosby, Altman General Contractors  
Michael Giwer, Monarch Construction Company



