



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

September 27, 2013

RE: TRUMBULL COUNTY
 HUBBARD TOWNSHIP
 5801 YOUNGSTOWN-HUBBARD RD
 SILVER STAR LOUNGE
 NPDES PERMIT NO.OH0143987
 OHIO EPA PERMIT NO. 3PR00531

Mr. William Pilorusso, Owner
 1089 Hubbard Rd.
 Lowellville, OH 44436

Mr. Pilorusso:

Ohio EPA performed a compliance evaluation inspection of the wastewater treatment works serving the above-referenced facility on August 28, 2013. The inspection was conducted to evaluate the operation and maintenance of the treatment system, and determine the facility's overall compliance with its National Pollutant Discharge Elimination System (NPDES) permit.

The existing 1,050-gpd treatment system consists of a grease trap, flow equalization basin, extended aeration activated sludge package plant, final settling tank, slow surface sand filtration, sludge holding, and UV disinfection. Treated effluent is discharged to an unnamed tributary of Crab Creek.

During the inspection, the following observations and/or deficiencies were noted:

1. The facility is closed for business, resulting in no discharge being observed.

A review of the facility's monthly electronic Discharge Monitoring Reports (eDMRs) received by Ohio EPA for the period May 2012 – August 2013 indicated violations of the terms and conditions in the NPDES permit. The specific instances of noncompliance include:

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
3PR00531*AD	June 2012	001	00530	Total Suspended Solids	30D Conc	12	15.1	6/1/2012
3PR00531*AD	August 2012	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	1.8	8/1/2012
3PR00531*AD	August 2012	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.5	1.8	8/1/2012

The eDMR review also indicated that reporting data for March 2013 and June 2013 was not submitted. Please log into your eBusiness account to submit the missing reports.

Please submit to this office, in writing, within 14 days' receipt of this letter, written documentation providing a status update on the facility's usage, as well as any future plans.

SILVER STAR LOUNGE
SEPTEMBER 27, 2013
PAGE 2

Should you have any questions or comments regarding this letter, please do not hesitate to contact this office at (330) 963-1120.

Respectfully,

A handwritten signature in cursive script that reads "Tomás Parry".

Tomás Parry, P.E.
Environmental Engineer II
Division of Surface Water

TP/cs

cc: Richard Curl, R.S., Trumbull County Board of Health