



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Crawford County
Tebo's Restaurant
NPDES Permit

October 4, 2013

Mr. R. Lyn Makeever
P.O. Box 325
Bucyrus, Ohio 44820

Dear Mr. Makeever:

On September 19, 2013, an inspection was made of the wastewater treatment facilities serving Tebo's Restaurant, located at 1221 State Route 61, Galion, Crawford County.

At the time of inspection, operation of the plant seemed fair. The aeration tanks appeared thin and dark and there was some foam. The aeration tanks were not receiving adequate air and there appeared to be a broken air line. The sludge return was operating, but was returning clear water. The sand in the sand filters needed to be leveled.

A review of the facility's discharge monitoring reports shows that reports are being made in a timely manner. The permit does not currently have limits, so compliance was not evaluated.

Please submit to us in writing **within 14 days of receipt of this letter** the steps that have been taken to repair the air line.

If you have any questions, please call me at 419-373-3019.

Sincerely,

A handwritten signature in cursive script that reads "Michelle Mix".

Michelle Mix
Environmental Specialist II
Division of Surface Water

/jlm
Enclosure

pc: Galion Health Department
Crawford County Health Department
Roger Oberlander, Owner
ec: Tracking

OHIO ENVIRONMENTAL PROTECTION AGENCY
 OPERATION AND MAINTENANCE INSPECTION
 WWTP'S LESS THAN 150,000 GPD

NPDES Permit No. 2PR00287

Facility Name Tebos Restaurant Expiration Date 4-30-18

Facility Location 1221 SR 61 Date 9-19-13 Time 1:40 am (pm)

City Galion County Crawford Township _____

Name of Owner Roger Obeclander Owner Phone _____

Person Contacted - Owner Email -

Operator of Record R Lyn Makeever Operator Email rmakeever@makeever.com

Flow: Design 10,000 GPD WWTP Classification: X A or 1

Trib. Pop. _____ (actual - estimated) Weather at time of inspection: Temp 70 ° - Cloudy

OEPA Personnel Michelle Mix District NWDO

1. Plant Effluent - Mark Severity No.

No.	Severity Description	Turbidity	Odor	Color
0	None	Clear	None	Colorless
1	Mild			
2	Moderate	Light Solids	Musty	Grey
3	Serious			
4	Extreme	Heavy Solids	Septic	Black

2. Effect of Effluent on Receiving Stream - Name: Not Observed

	None	Mild	Moderate	Serious

3. a. Plant has _____ excellent _____ good X fair _____ poor operation
 b. Plant has _____ excellent _____ good X fair _____ poor maintenance
 c. Sand filters have _____ excellent _____ good X fair _____ poor maintenance- N/A

Not operating at expected efficiency due to:

- (1) _____ hydraulic overload
 (2) _____ organic/solids overload
 (3) _____ personnel inefficiency
 (4) _____ equipment failure
 (5) _____ wastes
 (6) _____

Disinfection: (Required May 1 thru Oct. 31)	
IN	OUT
_____	_____
_____	_____
<u>NE</u>	_____

Chlorination Tablets
 Dechlorination Tablets
 Ultraviolet (U.V.)

Yes No

4. X _____ Compliance with NPDES Permit - Time Period: 5-1-13 to 9-1-13

	Y	N	Parameters:
Periodic Violations	_____	<u>X</u>	_____
Chronic Violations	_____	<u>X</u>	_____

5. NE O & M logbook kept and available on site: Location _____

6. NE Staffing Requirement Met (Class A - 2 days per week for minimum 1 hour per week)
 (Class I - 3 days per week for minimum 1.5 hours per week)

7. X Adequate Plant Safety: Deficiencies _____

Facility Name: Tebo's Restaurant

Process	# Units	Unit	If Needed - Description and Comments
Preliminary	X	Trash Trap	Pumping Frequency
		Grease Trap	Pumping Frequency
		Bar Screen	
		Comminutor	
		Flow Equalization	
Aeration Equipment	X	Plant Timer <u>X</u> Y ___ N	Cycle Time:
		Motor / Blower Unit	
Secondary Treatment	X	Aeration Tank	Color: <u>Dark, Foam</u> Adequate Aeration Y ___ N <u>X</u>
Final Settling	X	Clarifier	<u>OK</u>
		Sludge Return	In <u>X</u> Out <u>Clear</u>
		Surface Skimmer	In ___ Out ___
		Fixed Media Clarifier	
Tertiary Treatment	X	Surface Sand Filter	<u>OK, Needs leveled</u>
		Polishing Pond	
		Other	
Disinfection		Contact Tank	
		Chlorine Tube Feeder	
		Dechlorination Tube Feeder	
		Ultraviolet (UV)	
Flow Metering		Elapsed Pump Time	
		Recorder (continuous total)	
Pumps		Raw Wastewater (type)	
		Sand Filter Effluent Dosing	
Sludge Handling		Aerated Storage Tank	
		Sludge Drying Bed	
Sludge Disposal		Municipal POTW	
		Landfill	
		Land Application	
Advanced Treatment		Post Aeration	
		Spray Irrigation	
		Other	