



October 1, 2013

Joshua Wilhelm  
Transamerica Building Company Inc  
2000 W Henderson Road, Suite 500  
Columbus, Ohio 43220

**RE: Construction Storm Water Inspection at Bullet Ranch / Licking County  
Permit Number: 4GC04094\*AG**

Dear Mr. Wilhelm:

This letter is written regarding a storm water inspection I conducted at Bullet Ranch at 12425 East Broad Street on September 16, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- Silt fence has failed throughout the site and will require maintenance at this time.
- Please be aware measures are expected to ensure all barren areas are properly protected in preparation for the upcoming winter months. In the event earth disturbing activities extend beyond an effective growing season, alternate erosion protection is expected. This would include but not limited to a crimped straw mulch cover.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely

A handwritten signature in blue ink, appearing to read "Harry Kallipolitis".

Harry Kallipolitis  
Storm Water Coordinator  
Ohio EPA  
Division of Surface Water

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/slv Bullet Ranch 9-16-13