



October 1, 2013

Jeff Lacy
Sandlian Investments LLC
10913 East 126 Street
Fishers, IN 46038

**RE: Construction Storm Water Inspection at Cargo Storage/ Licking County Permit Number:
4GC04160*AG**

Dear Mr. Lacy,

This letter is written regarding a storm water inspection I conducted at Cargo Storage located at 143653 East Broad Street on September 11, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control

- Based on the site evaluation it appears a centralized basin is required. All affected areas should be routed to the basin intended for sediment control.
- All perimeter controls require maintenance and must be repaired within three (3) days of receipt of this letter.

Post Construction

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely

A handwritten signature in blue ink, appearing to read "Harry Kallipolitis".

Harry Kallipolitis
Storm Water Coordinator
Ohio EPA
Division of Surface Water

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO