



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

October 8, 2013

Mr. Doug Evans
 Broadwell Factory Group, LLC
 4229 Round Bottom Road
 Cincinnati, Ohio 45244

Certified Mail

**RE: Broadwell Factory Group, LLC Wastewater Treatment Works / 1IS00003
 Notice of Violation**

Dear Mr. Evans:

A compliance review was conducted on your Discharge Monitoring Reports (DMRs) submitted between May and August 2013. Screening your submitted DMRs has identified compliance issues; they are as follows:

EFFLUENT LIMIT VIOLATIONS
 (Period of Review: May – August 2013)

7D = Weekly 30D = Monthly 1D = Daily Conc. = Concentration (mg/l) Qty.=Quantity (Kg/Day)
 E.coli – cts/100 ml

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value
May 2013	001	Chlorine, Total Residual	1D Conc	0.019	.12
May 2013	001	Chlorine, Total Residual	1D Conc	0.019	.16
May 2013	001	Chlorine, Total Residual	1D Conc	0.019	.12
June 2013	001	Chlorine, Total Residual	1D Conc	0.019	.31
June 2013	001	Chlorine, Total Residual	1D Conc	0.019	.22
June 2013	001	Chlorine, Total Residual	1D Conc	0.019	.27
July 2013	001	Chlorine, Total Residual	1D Conc	0.019	.13
July 2013	001	Chlorine, Total Residual	1D Conc	0.019	.09
July 2013	001	Chlorine, Total Residual	1D Conc	0.019	.05
July 2013	001	Chlorine, Total Residual	1D Conc	0.019	.08
August 2013	001	E. coli	30D Conc	126	160.
August 2013	001	Chlorine, Total Residual	1D Conc	0.019	.12
August 2013	001	Chlorine, Total Residual	1D Conc	0.019	.09
August 2013	001	Chlorine, Total Residual	1D Conc	0.019	.05
August 2013	001	Chlorine, Total Residual	1D Conc	0.019	.06

Broadwell Factory Group
October 8, 2013
Page 2

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Non-compliance Notification".

If you should have any questions, feel free to contact me by phone at (937) 285-6029 or by electronic mail at joshua.jackson@epa.ohio.gov.

Respectfully,



Joshua Jackson
Environmental Specialist II
Division of Surface Water

JJ/kb

cc: John Beckman, Beckman Environmental Services
Anthony Muto, Broadwell Factory Group, LLC