



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

October 4, 2013

Mayor & Council  
Village of Clarksville  
P.O. Box 167  
Clarksville, Ohio 45113

**RE: Clarksville WWTW/Reconnaissance Inspection, NPDES Permit No. OH0127124  
OEPA Permit No. 1PA000024\*CD and Notice of Violation**

Ladies and Gentlemen:

On September 23, 2013, I conducted an NPDES Reconnaissance Inspection at the Village of Clarksville wastewater treatment works (WWTW). The final outfall and receiving stream were observed. The effluent was clear and there were no visible solids or foam. The required Outfall Sign was observed. A copy of the inspection report is enclosed.

A review of Clarksville's Discharge Monitoring Reports (DMRs) covering the months of October 2011 through August 2013 was performed. This review indicated limit violations of the condition of your NPDES Permit. The specific instances of noncompliance are noted at the end of the inspection report.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions, please contact me by phone at (937) 285-6028 or by email at [michelle.waller@epa.ohio.gov](mailto:michelle.waller@epa.ohio.gov).

Respectfully,

Michelle Waller  
Environmental Specialist II  
Division of Surface Water

MW/tb






State of Ohio Environmental Protection Agency  
Southwest District Office

NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
1PA00024*CD	OH0127124	9/23/2013	R	S	2

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Clarksville Wastewater Treatment Plant 160 Spring Hill Road Clarksville, Ohio 45113	12:45 PM	2/1/2011
	Exit Time	Permit Expiration Date
	1:00 PM	1/31/2016
Name(s) and Title(s) of On-Site Representatives	Phone Number(s)	
Name, Address and Title of Responsible Official	Phone Number	
Mayor & Council Village of Clarksville P.O. Box 167 Clarksville, Ohio 45113	(937) 289-2652	

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
N	Permit	N	Flow Measurement	N	Pretreatment
M	Records/Reports	N	Laboratory	N	Compliance Schedule
N	Operations & Maintenance	S	Effluent/Receiving Waters	N	Self-Monitoring Program
N	Facility Site Review	N	Sludge Storage/Disposal		Other
N	Collection System				

Section D: Summary of Findings (Attach additional sheets if necessary)	
See cover letter.	
Inspector	Reviewer
 Michelle Waller Division of Surface Water Southwest District Office	 Martyn Burt Compliance & Enforcement Supervisor Division of Surface Water Southwest District Office
10/4/13 Date	10/4/13 Date

**Notice of Violation  
Effluent Limit Violations  
(October 2011- August 2013)**

<b>Reporting Period</b>	<b>Parameter</b>	<b>Limit Type</b>	<b>Limit</b>	<b>Reported Value</b>	<b>Violation Date</b>
May 2013	Nitrogen, Ammonia (NH3)	7D Conc	1.5	4.55	5/1/2013
May 2013	Nitrogen, Ammonia (NH3)	7D Qty	0.51	.83353	5/1/2013
May 2013	Nitrogen, Ammonia (NH3)	30D Conc	1.0	1.67433	5/1/2013