



October 7, 2013

Rick Miller
Columbus Recreation & Parks Department
1111 East Broad Street
Columbus, Ohio 43205

**RE: Storm Water Inspection at Maryland Pool/ Franklin County. Permit #:
4GC04205*AG**

Dear Mr. Miller,

This letter is written in follow up to a construction storm water inspection conducted by Jerome Hoke and Elizabeth Pleta, of the Ohio EPA, at Maryland Pool located at 1380 Atcheson Street on September 23, 2013. The purpose of the inspection was to evaluate compliance with Ohio EPA's General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls


- Silt fencing is required along the fill portions on the south, east, and west sides of the site. Once silt fence is in place, it appears that the basin on site will be properly contained on site.
- If dewatering of these basins is required during construction, please ensure these activities do not result in discharge of turbid water to Waters of the State.
- Please be aware measures are expected to ensure all barren areas are properly protected in preparation for the upcoming winter months. In the event earth disturbing activities extend beyond an effective growing season, alternate erosion protection is expected. This would include, but not be limited to, a crimped straw mulch cover.

Post Construction Requirements

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCOA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Jeffrey P. Bohne
For H.K.

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO