



City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Erievue Plaza, Second Floor
Cleveland, Ohio 44114-1839
216/664-2297 • Fax: 216/420-8047
www.clevelandhealth.org

**SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY**

**CERTIFIED MAIL 7011 3500 0000 1759 8713
RETURN RECEIPT REQUESTED**

September 9, 2013

Adnan Wahdan
AAN Gas, Inc.
Warrensville Marathon
5012 Warrensville Center Road
Maple Heights, OH 44137

FACILITY ID: 13-18-37-7127

**RESOLUTION OF VIOLATIONS
NOTICE OF VIOLATION FOLLOW-UP LETTER**

Dear Mr. Wahdan:

On June 20, 2013, the Cleveland Division of Air Quality (CDAQ) inspected Warrensville Marathon located at 5012 Warrensville Center Road in Maple Heights.

On July 2, 2013, CDAQ issued a Notice of Violation requiring Warrensville Marathon to make necessary repairs to the Stage II vapor recovery system, and to schedule and successfully pass the Static Leak (SL) and Dynamic Pressure (DP) tests.

On August 22, 2013, CDAQ witnessed passing results of the SL and DP tests, and testing results were received. CDAQ has determined that no further enforcement action is warranted at this time, but reserves its right to take such action in the future if necessary.

CDAQ issues this letter with Ohio EPA's concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. Should you have any questions, please call Roman Fedorko at 216-664-4794. All correspondence with CDAQ must include the Ohio EPA facility identification number for Warrensville Marathon: 13-18-37-7127.

Sincerely,

Valencia White
Chief of Enforcement, CDAQ

VW/rf

cc: John Paulian, Ohio EPA Central Office
Brian Dickens, U.S. EPA Region V
L:\Data\Facilities\1318377127\2013-06-20 ROV+NEAR.docx