



**City of Cleveland**  
Frank G. Jackson, Mayor

Department of Public Health  
Division of Air Quality  
75 Erieview Plaza, Second Floor  
Cleveland, Ohio 44114-1839  
216/664-2297 • Fax: 216/420-8047  
www.clevelandhealth.org

**SERVING OHIO EPA AS AGENCY 13  
FOR CUYAHOGA COUNTY**

**CERTIFIED MAIL 7012 2210 0000 5209 4982  
RETURN RECEIPT REQUESTED**

9/19/13

Lorrie Brecker  
Lehigh Gas Corporation  
OHLG-UST1 dba 10202 Lorain Cleveland, LLC  
702 Hamilton St., Suite 203  
Allentown, PA 18101

**NON-HIGH PRIORITY FACILITY**

**RE: 10202 LORAIN AVENUE**

**FACILITY ID: 13-18-00-6926**

**RESOLUTION OF VIOLATIONS  
NOTICE OF VIOLATION FOLLOW-UP LETTER**

Dear Ms. Brecker:

On 8/26/13, the Cleveland Division of Air Quality (CDAQ) received notification from Tank Integrity Services, Inc. that OHLG-UST1 dba 10202 Lorain Cleveland, LLC located at 10202 Lorain Ave. in Cleveland had failed to successfully pass Stage II Vapor Recovery Testing on 6/26/13. And, that no retesting had been scheduled.

On 8/28/13, CDAQ issued a Notice of Violation requiring OHLG-UST1 dba 10202 Lorain Cleveland, LLC to schedule and retest the Static Leak (SL) and Air to Liquid Ratio (A/L) Stage II Vapor Recovery tests for emissions unit (EU) G001: Gasoline Dispensing Facility with Stage II vapor controls. And, submit the test results within thirty (30) days.

On 9/18/13, CDAQ received electronic copies of passing SL and A/L test results.

The corrective action plan was received in a timely manner and appropriate steps were taken to bring the source into compliance. CDAQ has determined that no further enforcement action is warranted at this time, but reserves its right to take such action in the future if necessary.



CDAQ issues this letter with Ohio EPA's concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. Should you have any questions, please call Dave DeChant at 216-664-3213. All correspondence with CDAQ must include the Ohio EPA facility identification number for 10202 Lorain Cleveland, LLC: 13-18-00-6926.

Sincerely,

A handwritten signature in cursive script that reads "Valencia White".

Valencia White  
Chief of Enforcement, CDAQ

VW/dd LK

cc: John Paulian, Ohio EPA Central Office  
Brian Dickens, U.S. EPA Region V  
L:\Data\Facilities\1318006926\2013-8-27 ROV+NEAR.docx