



City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Erieview Plaza, Second Floor
Cleveland, Ohio 44114-1839
216/664-2297 • Fax: 216/420-8047
www.clevelandhealth.org

**SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY**

**CERTIFIED MAIL 7012 2210 0000 5209 3961
RETURN RECEIPT REQUESTED**

September 26, 2013

Mohammed Al-Ahmad
Owner
Longwood Gas
3939 Community College Ave.
Cleveland, OH 44115-3316

NON-HIGH PRIORITY FACILITY

FACILITY ID: 13-18-00-6849

**NOTICE OF VIOLATION: FAILURE TO CONDUCT ANNUAL STAGE II VAPOR
RECOVERY TESTING**

Dear Mr. Al-Ahmad:

On September 6, 2013, the Cleveland Division of Air Quality (CDAQ) reviewed the records of Longwood Gas, located at 3939 Community College Avenue in Cleveland. This letter serves as notification that you are operating sources in violation of the following applicable air statutes, air regulations, or air permit conditions.

Longwood Gas is operating emissions unit, G001: Stage 1 and Stage 2 Gasoline Dispensing Facility, in violation of Ohio Administrative Code (OAC) rule 3745-21-09(DDD)(1)(c), in that applicable Stage II vapor recovery testing, as contained in OAC rule 3745-21-09(DDD)(2), has not successfully passed. This is also a violation of Ohio Revised Code (ORC) section 3704.05(G). The last successful tests were completed on July 19, 2012, and this year's tests should have been conducted by July 18, 2013.

Unless you undertake some type of corrective action with respect to the above noted violations, you will remain in non-compliance. CDAQ requests that Longwood Gas schedule and complete the static leak and air-to-liquid ratio tests and submit the test results within 30 days, to the following enforcement representative:

David Wagner
Cleveland Division of Air Quality
75 Erieview Plz., Fl. 2
Cleveland, OH 44114-1839



If you cannot submit the test results within 30 days, your written response to this letter must be received by CDAQ within 30 days of your receipt of this letter. If there is insufficient time to correct the alleged violations within this timeframe, your response must include a timeline for correcting the alleged violations.

Violations of Ohio air pollution laws and /or permit terms and conditions are subject to the penalties stipulated in ORC Section 3704.99(A), which allows fines of not more than \$25,000 or imprisonment for not more than one year, or both, for each violation.

Free assistance with state and/or federal regulations, rules, laws or permit conditions can be provided at no charge through Ohio EPA Office of Compliance Assistance and Pollution Prevention (OCAPP). OCAPP can be contacted at <http://www.epa.state.oh.us/ocapp> or 614/644-3469 or 800/329-7518. CDAQ makes no guarantee that the facility will meet the qualifying guidelines established by the OCAPP.

CDAQ issues this letter with Ohio EPA's concurrence. The failure to mention any specific violation does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. If you have any questions, please call David Wagner at 216/664-3004. All correspondence with CDAQ must include the Ohio EPA facility identification number for Longwood Gas: 13-18-00-6849.

Sincerely,

Valencia White
Chief of Enforcement, CDAQ

VW/dlw

cc: George P. Baker, CDAQ
Michael J. Krzywicki, CDAQ
John Paulian, Ohio EPA Central Office
Brian Dickens, U.S. EPA Region V
L:\Data\Facilities\1318006849\2013-09-26 NOV.docx