



City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Erieview Plaza, Second Floor
Cleveland, Ohio 44114-1839
216/664-2297 • Fax: 216/420-8047
www.clevelandhealth.org

**SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY**

**CERTIFIED MAIL 7012 2210 0000 5209 2964
RETURN RECEIPT REQUESTED**

October 9, 2013

Colleta Carter
Manager
Kmart Express #4966
7700 Brookpark Road
Brooklyn, OH 44129

FACILITY ID: 13-18-10-8334

**RESOLUTION OF VIOLATIONS
NOTICE OF VIOLATIONS FOLLOW-UP LETTER**

Dear Ms. Carter:

On August 2, 2013, the Cleveland Division of Air Quality (CDAQ) inspected Kmart Express #4966 located at 7700 Brookpark Road in Brooklyn.

On September 3, 2013, CDAQ issued a Notice of Violation requiring Kmart Express #4966 to schedule and test the Static Leak and Air-to-Liquid Ratio, and submit test results within thirty (30) days of receipt of the letter. CDAQ is in receipt of passing test results dated October 4, 2013, demonstrating that the Static Leak and Air-to-Liquid Ratio tests successfully passed on September 30, 2013.

The corrective action plan was received in a timely manner and appropriate steps were taken to bring the source into compliance. CDAQ has determined that no further enforcement action is warranted at this time, but reserves its right to take such action in the future if necessary.

CDAQ issues this letter with Ohio EPA's concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action.



Should you have any questions, please call Megan Murphy at 216-664-4258. All correspondence with CDAQ must include the Ohio EPA facility identification number for Kmart Express #4966: 13-18-10-8334.

Sincerely,

A handwritten signature in cursive script that reads "Valencia White".

Valencia White
Chief of Enforcement, CDAQ

VW/mm LK

cc: John Paulian, Ohio EPA Central Office
Brian Dickens, U.S. EPA Region V
L:\Data\Facilities\1318108334\2013-9-3 ROV + NEAR.doc