

PHASE 0 AD-HOC BARCODE SHEET

1/18/2012 3:47 PM

Department:




DAPC

Subdepartment:




<NONE>

Office Location:



LAA-ARAQMD

Media:



AIR

Doc Type:



NOV

Doc Subtype:



DAPC-Permit

Program:



DAPC-NON-TITLE V

County:



77 - SUMMIT

Facility ID



1677000574

Facility Name:
(Optional)



MACS CONVENIENCE 5410

(Auto Load)

Date:



1/13/2012

Record ID:
(Optional)





AKRON REGIONAL AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Summit County Health District
Serving Lorain, Portage and Summit Counties

TELEPHONE: (330) 375-2480

FAX: (330) 375-2402

January 13, 2012

Premise No: 1677000574

Mr. Jonathon Ross
Mac's Convenience Stores, LLC
PO Box 347
Columbus, IN 47202-0347

RE: NOTICE OF VIOLATION OF OAC RULE 3745-21-09 (DDD)-AT MACs 5410

Dear Mr. Ross:

Your Gas Dispensing Facility (GDF) is in violation of **OAC rule 3745-21-09 (DDD)(2), which specifies Stage II testing requirements and its frequency.** This facility was required to pass all necessary portions of Stage II testing on or before **January 5, 2011.** Your Stage II testing was not completed until **February 11, 2011.** This means that this GDF exceeded the permitted testing frequency by 37 days. Although the attempt to test on January 4, 2011, had your facility passed, would have been within the one year time frame, the exceedance of the allowable date is grounds for this Notice of Violation.

This agency is in receipt of the February 11, 2011 test result submitted by Tanknology for the Macs 5360 gasoline dispensing facility located at 6086 Darrow Road, located in Hudson and upon review, the test results are accepted as received and will be included in the operating file for this facility. However, acceptance of the information requested by this Agency does not constitute a waiver of this Agency's or the Ohio EPA's authority to seek civil penalties as provided in Section 3704.06 of the Ohio Revised Code. This Agency has the option to reject or accept late submittals. The determination to pursue or decline such penalties will be made at a later date.

This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Full compliance testing, as conducted at this facility, must be performed again within five year intervals according to the testing requirements of OAC rule 3745-21-09 (DDD)(2)(a)&(b). This facility will be due for **full testing** on or before **January 5, 2015.** Notification of testing is required as before, as well as reporting requirements.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact Harry Eckert at 330/375-2480 ext 3354

Sincerely,


Sam Rubens
Environmental Specialist Supervisor

146 SOUTH HIGH STREET • SUITE 904 • AKRON, OHIO 44308
An equal opportunity employer and provider of services

Printed on Recycled Paper