

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Gregg Budoi
E2 Energy USA
PO Box 2506
Mansfield, OH 44906

COMPLETE THIS SECTION ON DELIVERY

A. Signature Agent
 Addressee

B. Received by (Printed Name) C. Date of Delivery

BRUCE [unclear] 2/16/10
D. Is delivery address different from item 1? Yes
If YES, enter delivery address below: No

PO. BOX 2508
Mansfield OH 44906

3. Service Type
 Certified Mail Express Mail
 Registered Return Receipt for Merchandise
 Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee) Yes

2. Article Number
(Transfer from service label)

7003 1010 0004 2923 7384



City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Erieview Plaza, Suite 200
Cleveland, Ohio 44114-1839
216/664-2287 • Fax: 216/420-8047
www.clevelandhealth.org

SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY

CERTIFIED MAIL 7003 1010 0004 2923 7384
RETURN RECEIPT REQUESTED

February 9, 2010

Gregg Budoj
EZ Energy
PO Box 2506
Mansfield, OH 44906

FACILITY ID: 13-18-25-6969

NOTICE OF VIOLATION FOLLOW-UP LETTER: Failing Stage II testing; Failure to perform maintenance checks and maintain logs; Failure to conspicuously post fueling instructions which clearly state "Do Not Top Off"

Dear Mr. Budoj:

On January 11, 2010, the Cleveland Division of Air Quality (CDAQ) issued a Notice of Violation letter requiring Easy Trip #1111 to re-test the Air-to-Liquid (A/L) ratio on dispensers #6 and #8. CDAQ is in receipt of passing A/L ratio retest results on dispensers #6 and #8 that were performed on January 11, 2010.

The corrective action plan was received in a timely manner and appropriate steps were taken to bring the source into compliance. CDAQ has determined that no further enforcement action is warranted at this time, but reserves its right to take such action in the future if necessary.

CDAQ issues this letter with Ohio EPA's concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action.

Should you have any questions, please call Megan Murphy at 216-664-4258. All correspondence with CDAQ must include the Ohio EPA facility identification



number for Easy Trip #1111: 13-18-25-6969.

Sincerely,

Linda Kumomy for G.B.

George Baker
Chief of Enforcement, CDAQ

GB/mm

cc:

Michael J. Krzywicki, CDAQ
John Paulian, Ohio EPA Central Office
Lisa Holscher, U.S. EPA Region V
Facility File and L:\Data\Facilities\1318256969\2009-12-16 NEAR.doc