

**SENDER: COMPLETE THIS SECTION**

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Paramjit Singh - Santaj Oil  
1538 W 117th St.  
Lakewood, OH 44107

**COMPLETE THIS SECTION ON DELIVERY**

A. Signature

X *Ambreen 20/10/09*

Agent

Addressee

B. Received by (Printed Name)

C. Date of Delivery

*12-10-09*

D. Is delivery address different from item 1?  Yes

No

If YES, enter delivery address below:

3. Service Type

Certified Mail

Express Mail

Registered

Return Receipt for Merchandise

Insured Mail

C.O.D.

4. Restricted Delivery? (Extra Fee)

Yes



City of Cleveland  
Frank G. Jackson, Mayor

Department of Public Health  
Division of Air Quality  
75 Erievue Plaza, Suite 200  
Cleveland, Ohio 44114-1839  
216/664-7297 • Fax: 216/420-8047  
www.clevelandhealth.org

SERVING OHIO EPA AS AGENCY 13  
FOR CUYAHOGA COUNTY

CERTIFIED MAIL 7003 1010 0004 2923 7131  
RETURN RECEIPT REQUESTED

December 2, 2009

Paramjit Singh  
Sartaj Oil/ Shell # 2332  
1538 West 117<sup>th</sup> Street  
Lakewood, OH 44107

NON-HPV

FACILITY ID: 13-18-28-6800

NOTICE OF VIOLATION: Failing annual Stage II compliance test

Dear Mr. Singh:

On October 30, 2009, the Cleveland Division of Air Quality (CDAQ) inspected Sartaj Oil/Shell # 2332 (Sartaj Oil) located at 1538 West 117<sup>th</sup> Street in Lakewood. This letter serves as notification that you are operating sources in violation of the following applicable air statutes, air regulations, or air permit conditions.

CDAQ has determined that Sartaj Oil/ Shell # 2332 failed to successfully perform and pass an Air-to-Liquid Ratio test on dispensers #1, #2, and #3 as stipulated in Ohio Administrative Code (OAC) Rule 3745-21-09(DDD)(2). The failure to successfully pass the testing requirements in Ohio Administrative Code (OAC) Rule 3745-21-09(DDD)(2) for dispensers #1, #2, and #3 while causing, allowing or permitting the transfer of gasoline from a stationary storage tank into a motor vehicle are violations of Ohio Revised Code (ORC) Section 3704.05 (G) and Ohio Administrative Code (OAC) Rule 3745-21-09(DDD)(1)(c).

Unless you undertake some type of corrective action with respect to the above noted violations, you will remain in non-compliance. CDAQ requests that Sartaj Oil make the necessary repairs to dispensers #1, #2, and #3, then re-test the A/L ratio on dispensers #1, #2, and #3 and submit the test results within thirty (30) days as stipulated in OAC Rule 3745-21-09(DDD)(2)(c) to the following enforcement representative:

Megan Murphy  
Cleveland Division of Air Quality  
75 Erievue Plaza 2<sup>nd</sup> Floor  
Cleveland, Ohio 44114-1839



If there is insufficient time to correct the alleged violations within this timeframe, a written response that includes a timeline for correcting the alleged violations must be received within thirty (30) days of receipt of this letter.

Violations of Ohio air pollution laws and /or permit terms and conditions are subject to the penalties stipulated in Ohio Revised Code Section 3704.99(A), which allows fines of not more than twenty-five thousand dollars or imprisonment for not more than one year, or both, for each violation.

CDAQ issues this letter with Ohio EPA's concurrence. The failure to mention any specific violation does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. Should you have any questions, please call Megan Murphy at 216-664-4258. All correspondence with CDAQ must include the Ohio EPA facility identification number for Sartaj Oil: 13-18-28-6800.

Sincerely,

*Linda Kimmy for G.B.*

George Baker  
Chief of Enforcement

GB/MM

cc:

Richard Nemeth and Michael J. Krzywicki, CDAQ  
John Paulian, Ohio EPA Central Office  
Lisa Holscher, U.S. EPA Region V  
Facility File and L:/Data/Facilities/1318286800/2009-12-2 NOV.doc