

**SENDER: COMPLETE THIS SECTION**

- Complete items 1, 2, a. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Scott Moon  
Mayfield Road Center, LLC  
PO Box 1565  
Lawrenceville, GA 30046

2. Article Number

(Transfer from service label)

7009 3410 0002 1934 0298

**COMPLETE THIS SECTION ON DELIVERY**

A. Signature

X *Bill Smith*  Agent  Addressee

B. Received by (Printed Name)

C. Date of Delivery

Bill Smith 6-25-10

D. Is delivery address different from item 1?  Yes

If YES, enter delivery address below:  No

3. Service Type

- Certified Mail  Express Mail
- Registered  Return Receipt for Merchandise
- Insured Mail  C.O.D.

4. Restricted Delivery? (Extra Fee)

Yes



City of Cleveland  
Frank G. Jackson, Mayor

Department of Public Health  
Division of Air Quality  
75 Erieview Plaza, Suite 200  
Cleveland, Ohio 44114-1839  
216/564-2297 • Fax: 216/420-8047  
www.clevelandhealth.org

**SERVING OHIO EPA AS AGENCY 13  
FOR CUYAHOGA COUNTY**

**CERTIFIED MAIL 7009 3410 0002 1934 0298  
RETURN RECEIPT REQUESTED**

June 18, 2010

Scott Moon  
Hop-in Mayfield Road Center, LLC  
PO Box 1565  
Lawrenceville, GA 30046

NON-HPV

**FACILITY ID: 13-18-30-6226**

**NOTICE OF VIOLATION: Failing Stage II testing; Failure to provide proof of attendance and completion of training required by Ohio EPA**

Dear Mr. Moon:

On June 17, 2010, the Cleveland Division of Air Quality (CDAQ) inspected Mayfield Road Center, LLC located at 5332 Mayfield Road in Lyndhurst, Ohio. This letter serves as notification that you are operating sources in violation of the following applicable air statutes, air regulations, or air permit conditions.

Mayfield Road Center, LLC is in violation of Ohio Administrative Code (OAC) Rule 3745-21-09(DDD)(1)(c) which states that no owner or operator of a gasoline dispensing facility (GDF) may cause, allow, or permit the transfer of gasoline from a stationary tank at a GDF into a motor vehicle unless the vapor control system successfully passes the testing requirements contained in OAC Rule 3745-21-09(DDD)(2). On June 17, 2010 the dynamic pressure performance (blockage) test failed on all four dispensers.

Additionally, Mayfield Road Center, LLC failed to provide a Stage II compliance specialist certificate at the time of the inspection. This is a violation of OAC Rule 3745-21-09(DDD)(3)(a)(vi) which states: that any owner or operator of a gasoline dispensing facility must provide proof of attendance and completion of the training required by the Ohio EPA for the operator or local manager of the gasoline dispensing facility.

Unless you undertake some type of corrective action with respect to the above noted violations, you will remain in non-compliance. CDAQ requests that Mayfield Road Center, LLC make the necessary repairs to dispensers one through four, conduct re-test and submit test results, as well as submit proof of attendance and completion of required training within thirty (30) days to the following enforcement representative:

Megan Murphy  
Cleveland Division of Air Quality  
75 Erieview Plaza 2<sup>nd</sup> Floor  
Cleveland, Ohio 44114-1839



If there is insufficient time to correct the alleged violations within this timeframe, a written response which includes a timeline for correcting the alleged violations, must be received within thirty (30) days of receipt of this letter.

Violations of Ohio air pollution laws and /or permit terms and conditions are subject to the penalties stipulated in Ohio Revised Code Section 3704.99(A), which allows fines of not more than twenty-five thousand dollars or imprisonment for not more than one year, or both, for each violation.

CDAQ issues this letter with Ohio EPA's concurrence. The failure to mention any specific violation does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. Should you have any questions, please call Megan Murphy at 216-664-4258. All correspondence with CDAQ must include the Ohio EPA facility identification number for Mayfield Road Center, LLC: 13-18-30-6226.

Sincerely,

*Linda J. Jimmy for G.B.*

George Baker  
Chief of Enforcement

GB/mm

cc: Michael J. Krzywicki, CDAQ  
John Paulian, Ohio EPA Central Office  
Lisa Holscher, U.S. EPA Region V  
Facility File and L:\Data\Facilities\1318306226\2010-6-17 NOV.doc