

**SENDER: COMPLETE THIS SECTION**


- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Scott Moon  
Mayfield Rd. Center, LLC  
PO Box 1565  
Lawrenceville, GA 30046

**COMPLETE THIS SECTION ON DELIVERY**

A. Signature

X 

Agent

Addressee

B. Received by (Printed Name)

W. Dew

C. Date of Delivery

8/2/10

D. Is delivery address different from item 1?  Yes  
If YES, enter delivery address below:  No

3. Service Type

Certified Mail

Express Mail

Registered

Return Receipt for Merchandise

Insured Mail

C.O.D.

4. Restricted Delivery? (Extra Fee)

Yes

2. Article Number

(Transfer from service label)

7009 3410 0002 1934 0526



City of Cleveland  
Frank G. Jackson, Mayor

Department of Public Health  
Division of Air Quality  
75 Erieview Plaza, Suite 200  
Cleveland, Ohio 44114-1839  
216/664-2297 • Fax: 216/420-8047  
www.clevelandhealth.org

**SERVING OHIO EPA AS AGENCY 13  
FOR CUYAHOGA COUNTY**

**CERTIFIED MAIL 7009 3410 0002 1934 0526  
RETURN RECEIPT REQUESTED**

July 28, 2010

Scott Moon  
Hop-in Mayfield Road Center, LLC  
PO Box 1565  
Lawrenceville, GA 30046

**FACILITY ID: 13-18-30-6226**  
**RECEIPT OF CORRECTIVE ACTION PLAN: Failing Stage II testing; Failure to provide proof of attendance and completion of training required by Ohio EPA**

Dear Mr. Moon:

On June 18, 2010, the Cleveland Division of Air Quality (CDAQ) issued a Notice of Violation requesting that Hop-in Mayfield Road Center, LLC make the necessary repairs to dispensers one through four, conduct re-test and submit test results, as well as submit proof of attendance and completion of required training within thirty days of receipt of the letter. CDAQ witnessed a passing re-test of the blockage on July 21, 2010 and saw that the appropriate repairs have been made to the vapor return lines.

You are still expected to comply with submitting test results and proof of attendance and completion of training by August 13, 2010. Failure to do so may result in referral to Ohio EPA or U.S. EPA for further enforcement action. Fulfillment of your commitments included in the corrective action plan and/or any modifications contained within this letter does not constitute a waiver of CDAQ's ability to refer this matter to Ohio EPA or U.S. EPA for further enforcement action. Please submit any future correspondence related to this matter to the following enforcement representative:

Megan Murphy  
Cleveland Division of Air Quality  
75 Erieview Plaza 2<sup>nd</sup> Floor  
Cleveland, Ohio 44114-1839



CDAQ issues this letter with Ohio EPA's concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. Should you have any questions, please call Megan Murphy at 216-664-4258. All correspondence with CDAQ must include the Ohio EPA facility identification number for Hop-in Mayfield Road Center, LLC: 13-18-30-6226.

Sincerely,

*Linda Kimmy for G.B.*  
George Baker  
Chief of Enforcement, CDAQ

GB/mm

cc: John Paulian, Ohio EPA Central Office  
Lisa Holscher, U.S. EPA Region V  
Facility File and L:\Data\Facilities\1318306226\2010-6-17 RCAP.doc