

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Scott Moon
WC Rd, LLC.
PO Box 1565
Lawrenceville, GA 30046

2. Article Number
(Transfer from service label)

7009 3410 0002 1934 0717

PS Form 3811, February 2004

Domestic Return Receipt

102595-02-M-1540

COMPLETE THIS SECTION ON DELIVERY

A. Signature
X *Bill Smith* Agent Addressee

B. Received by (Printed Name) *Bill Smith* C. Date of Delivery *8-19-10*

D. Is delivery address different from item 1? Yes
If YES, enter delivery address below: No

3. Service Type
 Certified Mail Express Mail
 Registered Return Receipt for Merchandise
 Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee) Yes



City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Erieview Plaza, Suite 200
Cleveland, Ohio 44114-1839
216/664-2297 • Fax: 216/420-8047
www.clevelandhealth.org

SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY

CERTIFIED MAIL 7009 3410 0002 1934 0717
RETURN RECEIPT REQUESTED

August 12, 2010

Scott Moon
Hop-in Warrensville Center Road, LLC
PO Box 1565
Lawrenceville, GA 30046

FACILITY ID: 13-18-31-6227

RECEIPT OF CORRECTIVE ACTION PLAN: Failure to conduct Stage II testing; Failure to provide proof of attendance and completion of training; Failure to provide records of maintenance

Dear Mr. Moon:

On June 21, 2010 and August 4, 2010, the Cleveland Division of Air Quality (CDAQ) issued Notices of Violation requesting that Hop-in Warrensville Center Road, LLC complete the following requirements:

- Complete annual Stage II testing and submit test results
- Submit a copy of a Stage II compliance specialist certificate for Hop-in Warrensville Center Road, LLC once the required training has been completed
- Submit a corrective action plan stating how records of maintenance will be maintained in the future for a period of not less than three years and be made available to the director or any authorized representative of the director for review during normal business hours

CDAQ is in receipt of a Stage II compliance specialist certificate and a statement outlining the method for record retention for the facility dated August 11, 2010. You are still expected to comply with conducting stage II testing and submitting test results by September 3, 2010. Failure to do so may result in referral to Ohio EPA or U.S. EPA for further enforcement action. Fulfillment of your commitments included in the corrective action plan and/or any modifications contained within this letter does not constitute a waiver of CDAQ's ability to refer this matter to Ohio EPA or U.S. EPA for further enforcement action. Please submit any future correspondence related to this matter to the following enforcement representative:

Megan Murphy
Cleveland Division of Air Quality
75 Erieview Plaza 2nd Floor
Cleveland, Ohio 44114-1839



CDAQ issues this letter with Ohio EPA's concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. Should you have any questions, please call Megan Murphy at 216-664-4258. All correspondence with CDAQ must include the Ohio EPA facility identification number for Hop-in Warrensville Center Road, LLC: 13-18-31-6227.

Sincerely,

Linda Kimmy for G.B.
George Baker
Chief of Enforcement, CDAQ

GB/mm

cc: John Paulian, Ohio EPA Central Office
Lisa Holscher, U.S. EPA Region V
Facility File and L:\Data\Facilities\1318316227\2010-6-16 RCAP.doc