

AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

TELEPHONE: (330) 375-2480

FAX: (330) 375-2402

April 27th, 2012

Premise No: 1677130087

Mr. David S. Dodson
Environmental Compliance Manager
Sheetz, Inc.
5700 Sixth Avenue
Altoona, PA 16602-9938

REF: NOTICE OF VIOLATION

Dear Mr. Dodson:

Our Agency is in receipt of the February 3rd, 2012, Stage II test results submitted by Crompco for the Sheetz #393 gasoline dispensing facility located at 2495 Aurora Road in Twinsburg, however; these results are from a failed Air / Liquid Test. Subsequently, one of your employees retested this site the same day and passed it. The results from your employee are unacceptable as results must come from a certified testing company. Crompco has since returned to the site and conducted a passing Air/Liquid test.

This agency has yet to receive those passing results from Crompco's testing done on April 11th, 2012. **Sheetz is in violation of OAC rule 3745-21-09 (DDD)(2)(c) which requires that the results of Stage II testing be submitted to the Ohio EPA or its delegated local air agency within thirty days (30) following the completion of the tests.** The original tests for this location passed on **February 3rd, 2012**, however the passing results from Crompco have yet to be received. This Agency has the option to reject or accept late submittals.

Full compliance testing, as conducted at this facility, must be performed again within five year intervals according to the testing requirements of OAC rule 3745-21-09 (DDD)(2)(a)&(b). This facility will be due for **full testing on or before February 7th, 2016.** Notification of testing is required as before, as well as reporting requirements.

I would also like to remind you that the Static Leak Test and A/L testing as specified within the CARB Executive Orders and/or by this Agency must be performed annually, not to exceed one year from the last test performed. You are required to notify us before testing, and the results of the annual performance test are to be submitted within thirty (30) days of the test's completion.

Premise No: 1677130087

Mr. David S. Dodson
Environmental Compliance Manager
Sheetz, Inc.
5700 Sixth Avenue
Altoona, PA 16602-9938

I am sending you a copy of the Ohio Administrative Code outlining all testing procedures as well as time line submittals for such reports.

If you have any questions, please contact me at (330) 812-3949.

Sincerely,

A handwritten signature in cursive script that reads "Harry J. Eckert".

Harry J. Eckert
Environmental Specialist

HJE
enclosures