

**AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT**  
146 SOUTH HIGH STREET • SUITE 904 • AKRON, OHIO 44308  
TELEPHONE: (330) 375-2480 FAX: (330) 375-2404

May 1st, 2012

Premise No: 1667000017

Mr. Timothy J. Ujvari  
Ohio Turnpike Commission  
682 Prospect Street  
Berea, OH 44017

**REF: NOTICE OF VIOLATION**

Dear Mr. Ujvari:

Our Agency is in receipt of the January 26th, 2012, Stage II test results submitted by Crompco for the Sunoco Service Station gasoline dispensing facility located at 9250 Limeridge Road Plaza #7 South in Mantua.

Upon review, the test results are accepted as received and will be included in the Operating File for this facility. **However, the Ohio Turnpike Commission is in violation of OAC rule 3745-21-09 (DDD) (2) (c) which requires that the results of Stage II testing be submitted to the Ohio EPA or its delegated local air agency within thirty days (30) following the completion of the tests.** The test results for this location were received **April 27th, 2012.** This Agency has the option to reject or accept late submittals.

Full compliance testing, as conducted at this facility, must be performed again within five year intervals according to the testing requirements of OAC rule 3745-21-09 (DDD)(2)(a)&(b). This facility will be due for **full testing** on or before **March 29th, 2016.** Notification of testing is required as before, as well as reporting requirements.

I would also like to remind you that the Static Leak Test and A/L testing as specified within the CARB Executive Orders and/or by this Agency must be performed annually, not to exceed one year from the last test performed. You are required to notify us before testing, and the results of the annual performance test are to be submitted within thirty (30) days of the test's completion.

Premise No: 1667000017

Mr. Timothy J. Ujvari  
Ohio Turnpike Commission  
682 Prospect Street  
Berea, OH 44017

I am sending you a copy of the Ohio Administrative Code outlining all testing procedures as well as time line submittals for such reports.

If you have any questions, please contact me at (330) 812-3949.

Sincerely,



Harry J. Eckert  
Environmental Specialist

HJE  
Enclosure