

AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT
146 SOUTH HIGH STREET • SUITE 904 • AKRON, OHIO 44308
TELEPHONE: (330) 375-2402 • FAX: (330) 375-2402

TELEPHONE: (330) 375-2402

FAX: (330) 375-2402

April 27th, 2012

Premise No: 1667000016

Mr. Timothy J. Ujvari
Ohio Turnpike Commission
682 Prospect Street
Berea, OH 44017

RE: NOTICE OF VIOLATION

Dear Mr. Ujvari:

Our Agency is in receipt of the January 12th, 2012, Stage II test results submitted by Crompco for the Sunoco Service Station gasoline dispensing facility located at 9270 Limeridge Road Plaza #7 North in Mantua.

Upon review, the test results are accepted as received and will be included in the Operating File for this facility. **However, The Ohio Turnpike Commission is in violation of OAC rule 3745-21-09 (DDD)(2)(c) which requires that the results of Stage II testing be submitted to the Ohio EPA or its delegated local air agency within thirty days (30) following the completion of the tests.** The test results for this location were received **April 27th, 2012.** This Agency has the option to reject or accept late submittals.

Full compliance testing, as conducted at this facility, must be performed again within five year intervals according to the testing requirements of OAC rule 3745-21-09 (DDD)(2)(a)&(b). This facility will be due for **full testing** on or before **March 30th, 2016.** Notification of testing is required as before, as well as reporting requirements.

I would also like to remind you that the Static Leak Test and A/L testing as specified within the CARB Executive Orders and/or by this Agency must be performed annually, not to exceed one year from the last test performed. You are required to notify us before testing, and the results of the annual performance test are to be submitted within thirty (30) days of the test's completion.


Premise No: 1667000016

Mr. Timothy J. Ujvari
Ohio Turnpike Commission
682 Prospect Street
Berea, OH 44017

I am sending you a copy of the Ohio Administrative Code outlining all testing procedures as well as time line submittals for such reports.

If you have any questions, please contact me at (330) 812-3949.

Sincerely,

A handwritten signature in cursive script that reads "Harry J. Eckert".

Harry J. Eckert
Environmental Specialist

HJE
enclosures