



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 2, 2010

RE: ANNUAL STAGE II COMPLIANCE TEST  
FEBO'S MARATHON  
DAPC FACILITY ID 0243041348

CERTIFIED MAIL

Q MIC ✓  
3/27  
QW

Gary Febo  
9247 Chillicothe Road  
Kirtland, OH 44094

Dear Mr. Febo:

The annual Stage II compliance demonstration conducted at Febo's Marathon located at 9247 Chillicothe Rd. in Kirtland, Ohio on May 19, 2010, demonstrated compliance with the requirements of Ohio Administrative Code (OAC) Rule 3745-21-09(DDD).

The next annual Stage II compliance test is due in May 2011.

**This station is currently operating without permits in violation of OAC Rule 3745-31-02.**

I have enclosed a Permit by Rule Notification form. Please complete the form and return it as per the instructions **within fourteen (14) days of receipt of this letter.** This will replace any needed Permit-to-Install and Operate (PTIO) and will mean you no longer have to pay the biannual emission fees. Previous requests to submit this form have gone unanswered. **Failure to submit the completed form within the time frame above may result in a referral to Ohio EPA's Central Office for enforcement action.**

**Maintenance records required to be kept pursuant to OAC Rule 3745-21-09(DDD) were not being maintained in violation of OAC Rule 3745-21-09(DDD).**

Please begin keeping these records immediately and maintain them on site, available for inspection.

**The proof of attendance and completion of the training required by the Ohio EPA for the operator or local manager of the gasoline dispensing facility was not available in violation of OAC Rule 3745-21-09(DDD).**

I have enclosed a copy of the Rule that is applicable to gasoline dispensing facilities as well as a list of testing companies. Some of these companies conduct the Stage II training. **We will expect that the training will be completed prior to your next Stage II test.**

MR. GARY FEBO  
JUNE 2, 2010  
PAGE 2 OF 2

If you have any questions regarding this letter, please do not hesitate to contact me at (330) 963-1270.

Sincerely,



Tim Fischer  
Environmental Supervisor  
Division of Air Pollution Control

TF:bo

enclosures: Permit by Rule Notification form  
OAC Rule 3745-21-09(DDD)  
List of Stage II testing companies