



**Environmental
Protection Agency**

Ohio's
Governor
Lt. Governor
Director

August 31, 2011

RE: CERTIFIED WARNING LETTER
ANNUAL STAGE II COMPLIANCE TEST
SOUTH AMHERST SUNOCO
DAPC FACILITY ID 0247132001

CERTIFIED MAIL

Kim Green
South Amherst Sunoco
104 East Main Street
Amherst, OH 44001

Dear Ms. Green:

The annual Stage II compliance demonstration conducted at South Amherst Sunoco located at 104 East Main Street in Amherst, Ohio 44001 on April 18, 2011, failed to demonstrate compliance with the requirements of Ohio Administrative Code(OAC) Rule 3745-21-09(DDD).

The static leak portion of the testing on April 18, 2011, failed to demonstrate compliance. Failure to complete this testing is a violation of OAC Rule 3745-21-09(DDD).

I spoke with you on August 1, 2011 and you indicated that the testing company that you typically use would be called in to perform a retest. As of the date of this letter, no retest has been scheduled with this office.

Please schedule this testing within fourteen (14) days of receipt of this letter. Failure to schedule a retest will result in a referral to our Central Office for enforcement action.

Issuance of this Certified Warning Letter does not constitute a waiver of Ohio EPA's authority to seek civil penalties as provided in ORC 3704.06. Ohio EPA will decide whether to pursue or decline to pursue penalties regarding this matter at a later date.

If you have any questions regarding this letter, please do not hesitate to contact me at (330) 963-1270.

Sincerely,

Tim Fischer
Environmental Supervisor
Division of Air Pollution Control

TF:bo