



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

March 17, 2010

RE: ANNUAL STAGE II COMPLIANCE TEST  
BROADWAY LIBERTY GAS  
DAPC FACILITY ID 0247080680

Sung Yun  
Broadway Liberty Gas  
2436 Broadway Ave  
Lorain, Ohio 44055

Dear Mr. Yun:

The annual Stage II compliance demonstration conducted at Broadway Liberty Gas located at 2436 Broadway Ave in Lorain, Ohio on November 5, 2009 and January 27, 2010, demonstrated compliance with the requirements of Ohio Administrative Code (OAC) Rule 3745-21-09(DDD).

The next annual Stage II compliance test is due in November 2010 and will include the five-year dynamic pressure test.

The previous owner did not test this station in a timely manner. Please be sure to schedule the testing on time in the future. Also, this office considers more than 30 days to have a station retested once it fails to be excessive.

Several parts required replacement during this year's initial test. Please be sure to perform regular preventative maintenance to prevent this from happening on test day.

During the testing, maintenance records were not available in violation of OAC Rule 3745-21-09(DDD). **Please be sure to keep these records on site and available for inspection in the future.**

I have enclosed a Permit by Rule Notification form. This form was submitted by a former owner, but needs to be resubmitted with your new information. **Please complete the form and return it as per the instructions as soon as possible.**

I have also included a copy of the rule that applies to gasoline dispensing facilities for your convenience.

If you have any questions regarding this letter, please do not hesitate to contact me at (330)963-1270.

Sincerely,

Tim Fischer  
Environmental Supervisor  
Division of Air Pollution Control

TF:bo

enclosures: OAC Rule 3745-21-09(DDD)  
Permit by Rule Form