



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 24, 2010

RE: CERTIFIED WARNING LETTER
FIVE-YEAR STAGE II COMPLIANCE TEST
DAVE'S DYNA GUARD
DAPC FACILITY ID 0247120992

CERTIFIED MAIL

Brian Logue
300 Central Viaduct
Cleveland, OH 44115

Dear Mr. Logue:

The five-year Stage II compliance demonstration conducted at Dave's Dyna Guard located at 4095 Colorado Ave. in Sheffield Village, Ohio 44054 on March 17, 2010, demonstrated compliance with the requirements of Ohio Administrative Code (OAC) Rule 3745-21-09(DDD).

The next annual Stage II compliance test is due in March 2011.

Currently this station is operating without permits. I have enclosed a Permit by Rule Notification form. Please complete the form and return it as per the instructions **within fourteen (14) days of receipt of this letter**. This will replace any needed Permit-to-Install and Operate (PTIO) and will mean you no longer have to pay the biannual emission fees. **This is the third year in a row that this request has been made. Failure to complete and submit the form within fourteen days will result in referral to our Central Office for enforcement action.**

The proof of attendance and completion of the training required by the Ohio EPA for the operator or local manager of the gasoline dispensing facility was not available, in violation of OAC Rule 3745-21-09(DDD). I have enclosed a copy of the Rule that is applicable to gasoline dispensing facilities as well as a list of testing companies. Some of these companies conduct the Stage II training. **We will expect that the training be completed prior to your next Stage II test.**

Also, maintenance records were not maintained on site, in violation of OAC Rule 3745-21-09(DDD). **Please be sure to maintain these records on site and available for inspection in the future.**

If you have any questions regarding this letter, please do not hesitate to contact me at (330) 9631270.

Sincerely,

Tim Fischer
Environmental Supervisor
Division of Air Pollution Control

TF:bo

enclosures: Permit by Rule Notification form
OAC Rule 3745-21-09(DDD)
List of Testing Companies

pc: Station Manager