



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Road
Twinsburg, OH 44087-1924

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Laura H. Powell, Acting Director

January 29, 2007

RE: WARNING LETTER
ANNUAL STAGE II COMPLIANCE TEST
BLUE DIAMOND CITGO
OHIO EPA ID #0247081024

CERTIFIED MAIL

John Harb
Blue Diamond Citgo
3451 Colorado Ave.
Lorain, OH 44052

Dear Mr. Harb:

The annual Stage II compliance test conducted at Blue Diamond Citgo located at 3451 Colorado Ave. in Lorain, Ohio on January 22, 2007, demonstrated compliance with the requirements of Ohio Administrative Code Rule 3745-21-09 (DDD).

The next annual Stage II compliance test is due in January 2008.

Our inspector noted several problems during his inspection. The "No Topping Off" sign was missing. One of the hoses on dispenser #7 was cracked and in need of replacement. The proof of attendance and completion of the training required by the Ohio EPA for the operator or local manager of the gasoline dispensing facility was not available. I have enclosed a copy of the Rule that is applicable to gasoline dispensing facilities. We will reinspect the facility in the near future.

Additionally, please complete and return the enclosed permit-by-rule notification form.

If you have any questions regarding this letter, please do not hesitate to contact me at (330) 963-1223.

Sincerely,

Dennis Bush
Environmental Manager
Division of Air Pollution Control

DB:bo

enclosure(s)