



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korieski, Director

September 16, 2008

RE: WARNING LETTER  
ANNUAL STAGE II COMPLIANCE TEST  
SHEETZ, INC. #394  
DAPC FACILITY ID 0243081410

CERTIFIED MAIL

David Dobson  
Sheetz, Inc.  
5700 Sixth Ave.  
Altoona, PA 16602

Dear Mr. Dobson:

The annual Stage II compliance demonstration conducted at Sheetz #394 located at 7777 Reynolds Rd. East in Mentor, Ohio 44060 on August 18 and September 4, 2008, demonstrated compliance with the requirements of Ohio Administrative Code Rule 3745-21-09 (DDD).

Our inspector noticed that there was a drilled hole in one of the vapor caps. This is clearly a violation of the above cited rule. However, since it was promptly repaired, we are issuing this letter as a warning, rather than a Notice of Violation. As we discussed on the phone on Sept. 11, you consider this to be an isolated incident rather than a widespread problem. Nevertheless, please survey all Sheetz gasoline dispensing facilities in the Stage II areas of Ohio to ensure that this has not happened at other locations. If you find other Sheetz locations with the same problem, you need to notify the district office or local air agency of your findings.

The next Stage II compliance test is due in August 2009.

If you have any questions regarding this letter, please do not hesitate to contact me at (330) 963-1223.

Sincerely,

Dennis Bush  
Environmental Manager  
Division of Air Pollution Control

DB:bo

pc: Station Manager