



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 22, 2009

RE: NOTICE OF VIOLATION
FAILED ANNUAL STAGE II COMPLIANCE TEST
CONVENIENT FOOD MART #736
OHIO EPA ID #0247040926

CERTIFIED MAIL

Dennis Walter
ConSun Food Industries
123 North Gateway Blvd.
Elyria, OH 44035

Dear Mr. Walter:

The annual Stage II compliance test conducted at Convenient Food Mart #736 located at 8703 West Ridge Rd. in Elyria, Ohio 44035 on March 31, 2009, failed to demonstrate compliance for the following parameters:

<u>Parameter</u>	<u>Pass/Fail</u>
A/L Test	Failed
Static Leak Test	Passed
Dynamic Pressure Test	Not required this year
Ohio EPA Inspection	Passed

Dispensers #3 and #4 failed the A/L test.

Please schedule repairs and conduct a retest within 14 days of your receipt of this letter.

Failed test results constitute a violation of OAC Rule 3745-21-09 (DDD).

Violations of state air pollution control regulations are punishable by a civil penalty of \$25,000 per violation. Issuance of this notice does not excuse any violation of state law regarding air pollution. An enforcement action will be initiated if this site does not return to compliance within 14 days of your receipt of this letter.

Sincerely,

Dennis Bush
Environmental Manager
Division of Air Pollution Control

DB:bo

pc: Tim Fischer, DAPC, NEDO
Tom Kalman, DAPC, CO
Lisa Holscher, USEPA, Region V
Station Manager