



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

February 5, 2007

RE: NOTICE OF VIOLATION  
FAILURE TO CONDUCT ANNUAL  
STAGE II COMPLIANCE TESTING  
DAPC FACILITY ID #0243121349

**CERTIFIED MAIL**

Mr. Tony Continenza  
Perry One Stop  
29200 Euclid Ave.  
Wickliffe, OH 44092

Dear Mr. Continenza:

Our records indicate that Perry One Stop, located at 2500 North Ridge Road in Perry, Ohio did not conduct the required annual Stage II compliance testing in calendar year 2006. The most recent Stage II testing was conducted on March 30, 2005.

Ohio Administrative Code (OAC) Rule 3745-21-09 (DDD) requires testing of the Stage II vapor control equipment annually for static leak and air to liquid ratio, as well as every five years for dynamic pressure. A copy of the rule is attached. We have also attached a listing of testing companies that routinely conduct Stage II tests in Ohio. Please contact one of them to arrange for testing before February 28, 2007.

We strongly advise that you conduct maintenance on your Stage II vapor control equipment prior to having the testing conducted. Also, be sure to have all of the records required by paragraph 3 of the above-mentioned rule available for inspection during the test.

If you have any questions, please do not hesitate to contact me at (330) 963-1223.

Sincerely,

Dennis Bush  
Environmental Manager  
Division of Air Pollution Control

DB/mt

enclosures