



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

February 5, 2007

RE: NOTICE OF VIOLATION  
FAILURE TO CONDUCT ANNUAL  
STAGE II COMPLIANCE TESTING  
DAPC FACILITY ID #0247090720

CERTIFIED MAIL

Mr. Walid Abdelhalmid  
North Ridgeville Marathon  
35600 Center Ridge Rd.  
North Ridgeville, OH 44039

Dear Mr. Abdelhalmid:

Our records indicate that North Ridge Marathon, located at 35600 Center Ridge Road in North Ridgeville, Ohio did not conduct the required annual Stage II compliance testing in calendar year 2006. The most recent Stage II testing was conducted on March 7, 2005.

Ohio Administrative Code (OAC) Rule 3745-21-09 (DDD) requires testing of the Stage II vapor control equipment annually for static leak and air to liquid ratio, as well as every five years for dynamic pressure. A copy of the rule is attached. We have also attached a listing of testing companies that routinely conduct Stage II tests in Ohio. Please contact one of them to arrange for testing before February 28, 2007.

We strongly advise that you conduct maintenance on your Stage II vapor control equipment prior to having the testing conducted. Also, be sure to have all of the records required by paragraph 3 of the above-mentioned rule available for inspection during the test.

If you have any questions, please do not hesitate to contact me at (330) 963-1223.

Sincerely,

Dennis Bush  
Environmental Manager  
Division of Air Pollution Control

DB/mt

enclosures