



State of Ohio Environmental Protection Agency

**Northeast District Office**

2110 East Aurora Road  
Twinsburg, OH 44087-1924

TELE: (330) 963-1200 FAX: (330) 487-0789  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Laura H. Powell, Acting Director

January 29, 2007

RE: NOTICE OF VIOLATION  
FAILED ANNUAL STAGE II  
COMPLIANCE TEST  
CIRCLE K #5616  
DAPC FACILITY ID 0243161305

**CERTIFIED MAIL**

Tom Conti  
Circle K  
935 E. Tallmadge Ave.  
Akron, OH 44310

Dear Mr. Conti:

The annual Stage II compliance demonstration conducted at Circle K #5616 located at 37032 Vine St. in Willoughby, Ohio 44060 on January 4, 2007, failed to demonstrate compliance for the following parameters:

<u>Parameter</u>	<u>Pass/Fail</u>
A/L Test	Failed
Pressure Decay Test	Passed
Dynamic Pressure Test	Passed
Ohio EPA Inspection	Passed

The A/L test for dispensers 1, 2, 3, 4, 6, and 10 failed.

Failed test results constitute a violation of OAC Rule 3745-21-09 (DDD).

Please schedule repairs and conduct a retest within 30 days of your receipt of this letter.

Violation of state air pollution control regulations are punishable by a civil penalty of \$25,000 per violation. Issuance of this notice does not excuse any violation of state law regarding air pollution.