



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 11, 2009

RE: **WARNING LETTER**
ANNUAL STAGE II COMPLIANCE INSPECTION
CLARK #1301
OHIO EPA ID #0204030370

CERTIFIED MAIL

Plaxy Patel
Clark Oil #1301
125 Main St.
Geneva, OH 44041

Dear Ms. Patel:

The annual Stage II compliance demonstration conducted at Clark #1301 located at 125 Main St. in Geneva, Ohio on March 2, 2009, demonstrated compliance with the requirements of Ohio Administrative Code Rule 3745-21-09 (DDD).

Please be advised that paragraph 3 (vi) of the above rule requires that the operator or local manager of a Stage II system at a gasoline dispensing facility attend training on the operation of the system and that proof of attendance be available for our inspection. We expect that this training will be completed as soon as possible. Your testing company may be able to arrange for this training. You were advised of this requirement in our letter to you on April 5, 2006.

Also, our inspector noted that maintenance and gasoline delivery records were not being kept on site. This is also required by the above cited rule.

If the training and record keeping requirements are not corrected prior to your next test, this Agency will begin enforcement action.

The next compliance testing for this facility is due in March 2010.

If you have any questions regarding this letter, please do not hesitate to contact me at (330) 963-1223.

Sincerely,

Dennis Bush
Environmental Manager
Division of Air Pollution Control

DB:bo