



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Road
Twinsburg, OH 44087-1924

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Laura H. Powell, Acting Director

January 25, 2007

RE: NOTICE OF VIOLATION
FAILURE TO CONDUCT ANNUAL
STAGE II COMPLIANCE TESTING
DAPC FACILITY ID #0204000471

CERTIFIED MAIL

Peter Glor
Schmitt Fueling Growth
2101 St. Rita's Lane
Buffalo, NY 14221

Dear Mr. Glor:

Our records indicate that Orwell Sunoco, located at 23 South Maple St., in Orwell, Ohio, did not conduct the required annual Stage II compliance testing in calendar year 2006. The most recent Stage II testing was conducted on December 13, 2005.

Ohio Administrative Code (OAC) Rule 3745-21-09 (DDD) requires testing of the Stage II vapor control equipment annually for static leak and air to liquid ratio, as well as every five years for dynamic pressure. A copy of the rule is attached. We have also attached a listing of testing companies that routinely conduct Stage II tests in Ohio. Please contact one of them to arrange for testing before February 28, 2007.

We strongly advise that you conduct maintenance on your Stage II vapor control equipment prior to having the testing conducted. Also, be sure to have all of the records required by paragraph 3 of the above-mentioned rule available for inspection during the test.

If you have any questions, please do not hesitate to contact me at (330) 963-1223.

Sincerely,

Dennis Bush
Environmental Manager
Division of Air Pollution Control

DB:bo

enclosures