



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korieski, Director

July 2, 2008

RE: NOTICE OF VIOLATION  
FAILED ANNUAL STAGE II COMPLIANCE TEST  
CONVENIENT EXPRESS #747  
OHIO EPA ID #0247470529

**CERTIFIED MAIL**

0247070529

Dennis Walter  
Convenient Food Marts  
123 North Gateway Blvd.  
Elyria, OH 44035

Dear Mr. Walter:

The annual Stage II compliance test conducted at Convenient Express #747 located at 102 South Center St. in LaGrange, Ohio 44050 on July 1, 2008, failed to demonstrate compliance for the following parameters:

<u>Parameter</u>	<u>Pass/Fail</u>
A/L Test	Failed
Static Leak Test	Passed
Dynamic Pressure Test	Not required this year
Ohio EPA Inspection	Passed

There was no vacuum at dispensers #1 and #2 during the A/L test.

Please schedule repairs and conduct a retest within 14 days of your receipt of this letter.

Failed test results constitute a violation of OAC Rule 374521-09 (DDD).

Violations of state air pollution control regulations are punishable by a civil penalty of \$25,000 per violation. Issuance of this notice does not excuse any violation of state law regarding air pollution. An enforcement action will be initiated if this site does not return to compliance within 14 days of your receipt of this letter.

Sincerely,

Dennis Bush  
Environmental Manager  
Division of Air Pollution Control

DB:bo

cc: Bob Prinic, DAPC, NEDO  
Tom Kalman, DAPC, CO  
Lisa Holscher, USEPA, Region V  
Station Manager