



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 6, 2009

RE: NOTICE OF VIOLATION
MULTIPLE VIOLATIONS
UNI-MART #74775 FACILITY ID #0243111053
UNI-MART #04768 FACILITY ID #0204010403
UNI-MART #04767 FACILITY ID #0204030307

CERTIFIED MAIL

Patti Turiano
Uni-Mart, Inc.
477 E. Beaver Ave.
State College, PA 16801

Dear Ms. Turiano:

Over the past four years, Uni-Mart, Inc. has failed several Stage II compliance tests in violation of OAC Rule 3745-21-09(DDD) at the following locations:

Station	2006	2007	2008	2009
Uni-Mart #74775 6000 Vrooman Rd. Painesville, OH 44077	03/06/06 - failed static leak and A/L tests 04/24/06 - passed retest	10/30/07 - failed A/L test 01/23/08 - failed A/L test 03/25/08 - failed A/L test 03/28/08 - passed retest	11/12/08 - failed A/L test, did not retest	05/15/09 - failed A/L test
Uni-Mart #04768 4000 Park Ave Ashtabula, OH 44004	Did not test	12/03/07 - failed static leak and A/L tests 05/20/08 - passed retest	11/12/08 - failed static leak and A/L tests, did not retest	Has not tested
Uni-Mart #04767_1769 State Rte. 534 South Geneva, OH 44041	11/27/06 - failed A/L test 12/06/06 - passed retest	12/03/07 - failed static leak and A/L tests, did not retest	11/10/08 - failed A/L test, did not retest	Has not tested

Ms. Patti Turiano
Uni-Mart, Inc.
Page 2 of 2

Please schedule repairs and conduct retests of each of these stations **within thirty (30) days of your receipt of this letter.**

The proof of attendance and completion of the training required by the Ohio EPA for the operator or local manager of the gasoline dispensing facility was not available. I have enclosed a copy of the Rule that is applicable to gasoline dispensing facilities as well as a list of testing companies. Some of these companies conduct the Stage II training. We will expect that the training be completed prior to your next Stage II test. This is at least the third warning for each of these stations.

Violations of state air pollution control regulations are punishable by a civil penalty of up to \$25,000 per violation. Issuance of this notice does not excuse any violation of state law regarding air pollution. Due to the excessive failures and excessive amount of time before retesting, an enforcement action referral will be sent to the Central Office of Ohio EPA.

If you have any questions regarding this letter, please do not hesitate to contact me at (330) 963-1270.

Sincerely,



Tim Fischer
Environmental Supervisor
Division of Air Pollution Control

TF:bo

enclosures: OAC Rule 3745-21-09 (DDD)
List of Stage II testing companies

pc: Tom Kalman, Ohio EPA, NEDO, DAPC
Lisa Holscher, USEPA, Region V
Station Managers