



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 7, 2009

RE: ANNUAL STAGE II COMPLIANCE TEST AND
NOTICE OF VIOLATION FOR WELLINGTON
MICKEY MART #18 AND MICKEY MART #47
DAPC FACILITY IDS: 0247170525 &
0247100712

CERTIFIED MAIL

Dan Coles
Wellington Mickey Mart #18 and Mickey Mart #47
P.O. Box 449
Milan, OH 44846

Dear Mr. Coles:

The annual Stage II compliance determination conducted at the following locations failed to demonstrate compliance as there were too many leaks to be able to pass the A/L and Static Leak tests.

- September 21, 2009 - Wellington Mickey Mart #18 located at 508 Route 58 South in Wellington, Ohio 44090
- September 22, 2009 - Mickey Mart #47 located at 199 South Main St. in Oberlin, Ohio 44074 on

Failed test results constitute a violation of Ohio Administrative Code (OAC) Rule 3745-21-09(DDD).

To date, a retest has not been rescheduled resulting in continued violation of OAC Rule 3745-21-09(DDD). Please schedule repairs and conduct a retest **within 30 days of these failed tests.**

Furthermore, the 2008 test for Mickey Mart #47 was attempted on May 7, 2008, but also failed the static leak test and the A/L test. This station never passed the 2008 test in violation of OAC Rule 3745-21-09(DDD).